

A-ARCALENZ, LLC

Lead Abatement Contractor, Remediation,
Weatherization, RRP, Lead Evaluator Contractor

aarcalenzllc@gmail.com



571 Pleasant Valley Way,
West Orange, NJ 07052
Phone: 862 224 2356

LEAD IN WATER SAMPLING
OF
230 DIAMOND SPRING ROAD
DENVER NJ 07834

DATE: 07/24/2023

PREPARED FOR:

*Celebrate the Children School
230 Diamond Spring Road
Denville NJ 07834
Phone (C) 973-809-2392*

PREPARED BY
A-ARCALENZ LLC

TABLE OF CONTENT

SUMMARY

1. Methodology
2. Water Sample Analysis
3. Invoice

Methodology

APPENDIX A Laboratory results

1. Water Sample Collection

Leonard Duru of A-Arcalenz LLC who is a NJDOH certified and licensed Lead Inspector/Risk Assessor (Permit #: R001731; ID # R00572) collected water samples at all the specified locations within **230 Diamond Spring Road Denville NJ**. The collection of the water samples commenced at 7:15 am before the resumption of daily activities within the facility, this was to ensure that I collected the first draw from each point that was to be tested. The sampling was conducted on **July 11, 2023, and all the water samples were collected from water dispensers as directed by the facility manager.**

METHODOLOGY

The water samples were collected and analyzed following contract specifications.

1. Collect water samples at specified locations using 250ML bottles .
2. Store the water samples in a 250ml crew capped vial and assign a unique sample identification number.
3. Complete the chain of custody form
4. Send the samples along with chain of custody to NYSOH ELAP certified AIHA accredited laboratory for Lead dust analysis.

The water samples were analyzed by Enviro-Probe, INC laboratory at **6 Hollywood Court, 2nd Floor, Suite C, South Plainfield NJ 07080** (732) 494-4600. The laboratory is accredited by the AIHA. The results of the water samples are attached.

